

**Water Testing Section
Public Health Microbiology Laboratory
Medical Microbiology Department
University Hospital Galway**



Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number.: W-309/19	Issue Date: 08/03/2019	Page 1 of 1
---------------------------------	-------------------------------	--------------------

Sanitary Authority: Mayo County Council	SPS Sample: No
Supply Code: 2200 PRI 2557	Date of Sampling: 04-Mar-2019
Name of Supply: Callow Lake pGWS	Reason for Sampling: Repeat Sample
Sampling Point: _____	
Sample Taken by: _____	
Report to: _____ St. Marys Headquarters, Westport Rd., Castlebar, Co. Mayo	
Water Sample Type: Group Water Scheme - Private	
Treatment Status: Chlorinated	Temp of Water at Sampling Point: 2.7°C
Residual Chlorine: 0.17 ppm	Total Chlorine: 0.22 ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 05-Mar-2019 **Date Analysed:** 05-Mar-2019
Condition of Sample on Receipt: Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	not detected	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	not detected	MPN per 100ml
Cl.perfringens count	W5	Based on Env Agency UK: SCA MDW (2015) Part 6B	not detected	cfu per 100ml
Colony count per ml @ 22°C after 72 hrs	W4	Based on Environment Agency UK: MDW (2012) Part 7	none detected	cfu/ml

<hr style="border: 0; border-top: 1px solid black;"/> Authorised by: Quality Manager	<hr style="border: 0; border-top: 1px solid black;"/> Certified by: Consultant Microbiologist
--	---

THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL, AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY, MEDICAL MICROBIOLOGY DEPARTMENT, UNIVERSITY HOSPITAL GALWAY.
 * DENOTES NON-ACCREDITED TEST OR REPORT COMMENT



Feidhmeannacht na Seirbhíse Sláinte
Health Service Executive

OFFICIAL PUBLIC ANALYST'S LABORATORY REPORT

PUBLIC ANALYST
Email: PublicAnalystLab.UCHG@hse.ie
Telephone: (091) 58 11 22
Fax: (091) 58 12 12

Public Analyst's Laboratory,
University Hospital,
Seamus Quirke Road,
Galway, Ireland

Lab Ref Number: W560-2019

Date Printed: 29/03/2019

Drinking Water Regulations S.I. No. 122 of 2014:- VOLATILE ORGANIC COMPOUNDS

Name of Supply: Callow Lake GWS Authority Mayo County Council

Sampling Point:

Sampling Reason: Operational

Requested by: EPA Ref No. 2200PRI2557

Date & Time Sampled 04/03/2019 12:30:00 Date Received: 05-March-2019

REPORT TO:

Castlebar Environmental Health Department
Community Services, 3rd Floor
St. Mary's Headquarter's
Westport Road
Castlebar
Co. Mayo

Test No.	Parameter	Parametric Value	Method No.	Units	Result
27	Chloroform		2/81	µg/L	52
27	Bromodichloromethane		2/81	µg/L	24
27	Dibromochloromethane		2/81	µg/L	6
27	Bromoform		2/81	µg/L	<1
27	Total	100	2/81	µg/L	82
26	Tetrachloroethene		2/81	µg/L	<2
26	Trichloroethene		2/81	µg/L	<2
26	Total	10	2/81	µg/L	<5
14	1,2-DiChloroethane	3	2/81	µg/L	<0.3
6	Benzene	1	2/81	µg/L	<0.25

Report Status Authorised



Executive Analytical Chemist

Note 1: This report shall not be reproduced except in full, without written approval of the Laboratory

Note 2: This test report relates only to the sample tested.

Note 3: Any opinions, remarks and/or interpretations expressed above are outside the scope of accreditation

Blue type indicates a result that does not comply with the Parametric Value or Range & is outside the scope of accreditation.

Red type indicates a result that does not comply with the Parametric Value or Range.